

March 6, 2026

ADDENDUM NO. 2

TO THE  
CONTRACT DOCUMENTS FOR  
PART A - BENNETTS CREEK CROSSING –  
DWI PROJECT No.SRP-D-134-153 – CN1  
PART B - CARTERS ROAD DIRECTION BORE –  
DWI PROJECT No. SRP-D-134-153 – CN2  
PART C - GATESVILLE TRANSMISSION MAIN –  
DWI PROJECT No.SRP-D-134-154 – CN1  
PART D - HIGHWAY 158 WATER SYSTEM IMPROVEMENTS –  
DWI PROJECT No.SRP-D-134-154 – CN2  
GATES COUNTY, NORTH CAROLINA

**Bid Date:** March 12, 2026 – 2:00 P.M.

**From:** Green Engineering, P.L.L.C.  
Consulting Engineers  
Wilson, North Carolina

**NOTICE TO BIDDERS:**

This Addendum is issued prior to the receipt of bids for the above project and **must be** acknowledged on **Page 6 of 10 of the BID FORM** where indicated.

The CONTRACT DOCUMENTS for this work are modified as follows:

**I. REQUEST FOR INFORMATION**

Below we are questions that have been submitted in writing and our responses to those questions are provided in red.

1. Do you have an engineer's estimate for the project? **The Engineer's Construction Cost Estimate for Parts A, B, C & D is ±\$3,816,436.00.**
2. How is the project being funded? **This project is being funded from the Drinking Water/Wastewater State Reserve as established in Session Law (S.L.) 2023-134 and amended in S.L. 2024-1 (S.L. 2023-134).**
3. Can the bid be extended by one (1) week? **The Bid cannot be extended. If however, there are less than three (3) bids received on March 12, 2026, the project will be readvertised.**
4. Can fusible PVC be used in lieu of HDPE for the directional bores? **No. All references to fusible PVC shall be deleted from the project Specifications.**

END OF ADDENDUM NO. 2